

LOCKOUT/TAGOUT PROCEDURE OSHA CFR 1910.147

Developed by	Reviewed by	Revised by
RA	RA	
Description: Condenser Water Filtration Pump		Equipment #: CP-F-2
Building: South Chilled Water Plant	Area: Second Floor	Rev: 0
Date: N/A	Origin Date: 12/18/2017	

3  **Isolation Points to be Locked and Tagged**

Safety Is Your Responsibility!




South Side View



East Side View



ALWAYS PERFORM A MACHINE STOP BEFORE LOCKING OUT DISCONNECTS

ID	Source	Device	Location	Method	Check
	Electrical 480V	Padlock	Isolation point located on panel MCC-2.	Move electrical disconnect "Basin Filter Pump" to off. Lock out.	Verify machine is deenergized.
	Filtration Water Suction - 100 PSI	Cable device	Isolation point on West side of unit.	Turn valve to closed position. Lock out.	Visually verify zero pressure status.
	Filtration Water Discharge - 100 PSI	Cable device	Isolation point on East side of unit.	Turn valve to closed position. Lock out.	Visually verify zero pressure status.



OPENING A GUARD DOES NOT CONSTITUTE A LOCKOUT
ALWAYS VERIFY DE-ENERGIZATION OF EXPOSED ELECTRICAL PARTS AND RESIDUAL CAPACITANCE

Any machine modifications must be shown in procedure.
Contact EHS to update procedure: 603-646-1762

